

PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 01 / 2024-25Date: 20.04.2024It is certified that an inspection team headed by Mr. VENU GOPAL. B.N.(Name of Officers with designation) from SENIOR HEALTH INSPECTOR.(Name of Department/Office) inspected the HEALTH SECTION. SHIMOGA CORPORATION.(Name & Address of the School) on 20.04.2024 (Date of Inspection) and found that theSANDEEPINI ENGLISH SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.The above is valid for a period of 06 MONTHS

Signature with Seal

Name: AMOL S. SHIVAMOGGA Assistant Executive Engineer (Env.)
Shivamogga City CorporationDesignation: ASSISTANT EXECUTIVE ENGINEER (ENV)
SHIVAMOGGAName & Address of the office/Department: Shivamogga City Corporation Shivamogga

To,

SecretarySANDEEPINI EDUCATIONAL TRUST
SANDEEPINI ENGLISH SCHOOL SHIVAMOGGA
(Name & Address of the Institution)

- The Filled up certificate should be either in Hindi or English. If it is issued in vernacular language translated notarized version in English be uploaded along with the Original vernacular certificate has a single pdf.



ರಾಷ್ಟ್ರೀಯ ಶಿಕ್ಷಣ ಸಮಿತಿ(ರಿ.), ಶಿವಮೊಗ್ಗ.
National Education Society(R.), Shivamogga.

Jawaharlal Nehru National College of Engineering, Shivamogga.

ಜವಾಹರ್‌ಲಾಲ್ ನೆಹರು ರಾಷ್ಟ್ರೀಯ ತಾಂತ್ರಿಕ ಮಹಾವಿದ್ಯಾಲಯ, ಶಿವಮೊಗ್ಗ.



(Approved by A.I.C.T.E.New Delhi, Certified by UGC 2f & 12B, Accredited by NAAC - 'B', Recognised by Govt. of Karnataka and Affiliated to VTU, Belagavi)

DEPARTMENT CIVIL ENGINEERING

(Accredited by NBA)

Ref. No.: JNNCE/ CE / 075 / 2024 - 25
To,

Date: 11/07/2024

Head Master,
Sandipini English School,
Arvinda Nagara,
Shimoga.

Sir,

Sub: Testing of Water sample for drinking purpose.

Ref: Your letter No. Nil Dated 09/07/2024.

Sl. No	Parameters	Units	Obtained values	Limits as per IS 10500: 2012
1	p ^H	-	08.30	6.50 - 8.50
2	Acidity	mg/L	28.00	-
3	Alkalinity	mg/L	42.00	Up to 200
4	Hardness	mg/L	128.00	Up to 600
5	Calcium	mg/L	48.00	Up to 75
6	Chloride	mg/L	110.00	Up to 250
7	Dissolved oxygen	mg/L	02.80	-
8	Odour	-	Nil	-
9	Color	-	Nil	-
10	Turbidity	NTU	04.20	Up to 05
11	Total dissolved solids	mg/L	34.00	Up to 500
Potable / Non Potable			Potable	-

Disclaimer:

1. The tests are carried out on the samples as received and supplied by the customer.
2. The scope of the sample test results and reports thereof are limited to ascertain as to which standard the supplied samples confirm to.
3. The results are purely based on the parameters listed above and tested in our laboratory. The results are subjected to vary based upon the other parameters which are not listed here and not tested in our laboratory.
4. The tests carried out and report given does not endorse suitability of the material for the intended purpose.
5. This report cannot be reproduced wholly or in part and cannot be used as evidence in the court of law.
6. Any dispute arising out of this report is subject to Shivamogga jurisdiction only.
7. The college or personnel involved in testing is not responsible for any miss happenings due to usage of the tested material in any form or condition.
8. Location of water sample / Name of the work are as mentioned in the client's letter under reference.

Raghavendra. S
Lab Instructor

Dattakrishna. S
Staff in charge

[Signature]
Coordinator
11/07/2024
[Signature]
H.O.D
11/7/2024

ನವುಲೆ, ಶಿವಮೊಗ್ಗ - 577 204, ಕರ್ನಾಟಕ

Navule, Shivamogga - 577 204, Karnataka

E - mail : hod_civil@jnnce.ac.in Website : www.jnnce.ac.in

: 08182 - 276707 / 08 / 09, 268800 / 1, Fax : 08182 - 222450